



ADDENDUM NO. 1

ITB 442-9030
Purchase of Trailer
Mounted Sewer Pumps

ISSUED April 1, 2004

1. Paragraph 2.02 stated the specifications listed were descriptive of a Thompson Model 6TS-DJDST-4045D-MC brand trailer/skid mounted sewage pump. The model number should have been listed as **6TSV**-DJDST-4045D-MC or equivalent.

2. Paragraph 2.02D is supplemented as follows:

The engine should be a John Deere 4045D or equivalent, with maximum 80 hp and a minimum continuous duty of 63 hp at 1800 rpm.

3. Paragraph 2.02E is supplemented as follows:

The enclosure should be constructed with an aluminum frame and 2 inch thick galvanized steel panels. The panels should be a sandwich construction of an 18 gauge solid outer shell, acoustical insulating fill with moisture barrier and a 22 gauge perforated inner liner. Enclosure should have hinged, lockable doors allowing full access to the pump and engine for routine maintenance without disassembling and removing panels or disconnecting the suction lines.

4. Paragraph 2.02F is supplemented as follows:

The vacuum assisted suction lift capacity should be 30 feet, fast priming. Pump performance: closed discharge (max. shutoff head) of 172 feet; max. flow of 1750 gpm.

5. Bid opening date has been rescheduled to **2:00 p.m. April 20, 2004.**

Please sign and return this addendum, either with your bid or under separate cover, on or before the revised opening date of this bid. If submitting this addendum under separate cover, please indicate the bid number and opening date on the face of your envelope in the lower left-hand corner. Bidders may retrieve their bids or send a corrected copy prior to the revised bid opening date.

All other terms, conditions, and specifications remain unchanged.

Kirk W. Buffington, C.P.M.
Assistant Director, Administrative Services

Company
Name: _____
(please print)

Bidder's
Signature: _____

Date: _____